

## Pre- Application Testing Requirements

Required application tests must be submitted with completed application and must have been completed within 6 months of the date of application. Requirements will vary based on the site specific configuration of the tank system installed. Some of the items listed below will not apply to your system.

1. Full Tank Tightness Test\*
2. Line Tightness Test
3. Line Leak Detector Test
4. Spill Bucket Test
5. Sump Containment Test
6. Dispenser Containment Test
7. Overfill Test
8. Tank Monitor Certification
9. Current Cathodic Protection Test
10. Tester Statement – “All tests were completed after all hard surfaces (concrete, asphalt, etc.) were installed.”

\*A Full Tank Tightness Test can be completed by a qualified 3<sup>rd</sup> party service provider or via the Automatic Tank Gauge if your system is configured to perform a 0.1 GPH precision test at the appropriate overfill ratio.